



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5142BP5597

Registration Number
Registriernummer

Field of Application

Anwendungsbereich

products of gas supply

Produkte der Gasversorgung

Owner of Certificate

Zertifikatinhaber

Henkel AG & Co. KGaA

Henkelstraße 67, D-40589 Düsseldorf

Distributor

Vertreiber

Henkel AG & Co. KGaA

Henkelstraße 67, D-40589 Düsseldorf

Product Category

Produktart

Greasing and sealing materials: Sealing and jointing materials for gas installations and hot water, non hardening (5142)

Product description

Produktbezeichnung

Non-hardening sealant in the form of an impregnated cord for threaded connections for gas installations and for water heating systems

Model

Modell

Tangit UNILOCK

Test reports

Prüfberichte

Type testing: 19/102/5142/2 from 28.11.2019 (EBI)

Supplement test: 23-00291-AB02 from 21.11.2024 (EBI)

Laboratory control test: 22-00346-KP03 from 26.07.2024 (EBI)

Test basis

Prüfgrundlagen

DIN EN 751-2 (01.08.1997)

Date of Expiry / File No.

Ablaufdatum / Aktenzeichen

26.11.2029 / 24-0343-GNV

11.12.2024 Fi A-1/2

Date, Issued by, Sheet, Head of Certification Body

Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

J. Bohmich



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type	Technical Data	Remarks
Typ	Technische Daten	Bemerkungen
Tangit UNILOCK	Class: ARp	

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

temperature range / pressure range (gas): -20...+70 °C / ≤ 5 bar

temperature range / pressure range (hot water): up to +130 °C / ≤ 7 bar

certification assessment was additionally carried out on the basis of the supplementary test reports 22-00191-AB01, 22-00192-AB01, 22-00193-AB01, 22-00194-AB01, 23-00292-AB01, 23-00293-AB01, 23-00294-AB01 and 23-00295-AB01 dated 31.05.2023, 24-00287-AB01 and 24-00288-AB01 dated 21.11.2024.