

EU type examination certificate**EU-Baumusterprüfbescheinigung****CE-0085CP0089**Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Distributor <i>Vertreiber</i>	BAXI Calefacción, S.L.U. Salvador Espriu, 9, E-08908 L'Hospitalet de Llobregat-Barcelona
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing water heater (3202)
Product Description <i>Produktbezeichnung</i>	floor standing condensing water heater with automatic burner control and gas/combustion-air ratio control
Model <i>Modell</i>	Power HT PLUS...
Countries of Destination <i>Bestimmungsländer</i>	AL, AT, BG, BY, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, PL, PT, RO, RU, SE, SI, SK, TR, UA
Test Reports <i>Prüfberichte</i>	supplement test: 18/167/3204/417 from 05.10.2018 (EBI) supplement test: 18/167a/3204/417 from 12.11.2018 (EBI)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.09.2017)

Date of Expiry / File No. 12.03.2028 / 18-0824-GER
Ablaufdatum / AZ

10.01.2019 Rie C-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Elektrical Data
Elektrische Daten

230 V AC, 50 Hz, IP21

Appliance Categories <i>Gerätekategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2H	20 mbar	LV	
I3P	30 mbar	IS, MT	
II2E3P	20, 37 mbar	LU	
II2E3P	20, 50 mbar	DE	
II2ELw3P	20, 37 mbar	PL	
II2Esi3P	20/25, 37 mbar	FR	
II2H3P	20, 30 mbar	DK, EE, FI, LV, NO, RO, SE, SI	
II2H3P	20, 37 mbar	CH, CZ, ES, GB, GR, HR, IE, IT, PT, SK, TR	
II2H3P	20, 50 mbar	AT	
II2HM3P	20, 37 mbar	IT	only types Power HT PLUS 50 up to 110
II2HS3P	25, 30 mbar	HU	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
POWER HT PLUS 50	nominal heat output: 5,0...45,0 kW heat input (Hi): 5,1...46,3 kW	
POWER HT PLUS 70	nominal heat output: 7,2...65,0 kW heat input (Hi): 7,4...66,9 kW	
POWER HT PLUS 90	nominal heat output: 9,4...85,0 kW heat input (Hi): 9,7...87,4 kW	
POWER HT PLUS 110	nominal heat output: 11,4...102,0 kW heat input (Hi): 11,7...104,9 kW	
POWER HT PLUS 130	nominal heat output: 24,3...121,5 kW heat input (Hi): 24,8...123,8 kW	
POWER HT PLUS 150	nominal heat output: 28,1...140,3 kW heat input (Hi): 28,6...143,0 kW	
POWER HT PLUS 200	nominal heat output: 31,0...185,9 kW heat input (Hi): 31,8...191,0 kW	
POWER HT PLUS 250	nominal heat output: 38,8...232,8 kW heat input (Hi): 40,0...240,0 kW	

Hints of Utilization /Remarks
Verwendungshinweise / Bemerkungen

Flue types (only for types POWER HT PLUS 50 up to POWER HT PLUS 150) B23, B23P, C13(x), C33(x), C43(x), C53(x), C63(x) and C83(x): according to installation manuals no. 7609489 (ES) and 7609491 (PT)

Flue types (for types POWER HT PLUS 200 and POWER HT PLUS 250) B23, B23P, C13, C33, C43, C53, C63 und C83: according to installation manuals no. 7609489 (ES) and 7609491 (PT)

The condensing boilers POWER HT PLUS 130 bis POWER HT PLUS 250 with flue type B23 can be installed as cascade with up to 4 appliances of the same type.

Additionally tested appliance categories, supply pressures and countries of destination:

CY: I2H (20 mbar)

LV: II2E3P (20, 30 mbar)

BY, CY, RU, UA: II2H3P (20, 30 mbar)

AL, BG, MK: II2H3P (20, 37 mbar)

In Albania, Belarus, Macedonia, in the Russian Federation and in the Ukraine the CE-marking will be accepted as conformaty approval if the EU-Gas Appliance Regulation (EU/2016/426) is transferred into national law by Albania, Belarus, Macedonia, the Russian Federation respectively by the Ukraine.

DVGW